

**JORDAN VALLEY WATER CONSERVANCY DISTRICT
2022 DISTRIBUTION PIPELINE REPLACEMENTS
REDMAPLE AREA**

JANUARY 2022

ADDENDUM NO. 1

PART 1 – GENERAL

- A. The following ADDENDUM shall be made part of the Bidding Documents, and the Bidder shall acknowledge receipt thereof on page C-1 of the BID. The addendum consists of 4 pages of written text (including this cover sheet).

- B. This addendum does not change the bid date. It is still Thursday, January 20, 2022, at 3:30 P.M.

1.1 DOCUMENTS INCLUDE

- A. Changes to the Bid Documents.

1.2 CLARIFICATIONS

- A. The minimum size for the bypass piping to be installed along Redmaple Road, shall be of 6-inch diameter. The size of the bypass piping was increased to accommodate fire flow requirements and to remove the 4/15/2022 completion deadline for Redmaple, 810 East, and White Maple roadways. The 6-inch diameter bypass piping is to be installed within a shallow trench, with minimum of 1-foot of cover or additional amount of cover as the Contractor deems necessary to adequately protect the bypass piping.

- B. The minimum size for the bypass piping to be installed along 3680 South, shall be of 2-inch diameter.

PART 2 - CHANGES

Addendum to include Location and Description of Change:

Item	Location	Description of Change
1.	Section 01010-3 SUMMARY OF WORK	Delete Paragraph 1.05.B.1 and replace with the following: The CONTRACTOR shall complete all work for the pipeline installation and abandonment of the existing waterlines along Redmaple Road, 810 East, and Whitemaple Road prior to the replacement of the remaining waterlines for the project. This work will include, but not limited to: <ul style="list-style-type: none">a. Temporary connection near 710 E Redmaple;b. cut-in three new gate valves at 700 E Redmaple;c. install bypass piping and temporary service connections;

		<p>d. disinfection and testing of bypass piping and watermains;</p> <p>e. connect all services to the new watermain; and</p> <p>f. perform required abandonments.</p> <p>g. All surface restoration for the areas listed above to be completed prior to the replacement of the remaining waterlines for the project.</p>
2.	<p>Section 01020-8 MEASUREMENT AND PAYMENT</p>	<p>Delete Bid Item #23 and replace with the following:</p> <p>Bid Item #23: Bypass Waterlines & Temporary Service Connections</p> <ol style="list-style-type: none"> 1. Measurement: Lump Sum 2. Payment Covers: Furnishing all labor, materials, tools, equipment, concrete and landscape removal and restoration, and all incidentals required for the installation, flushing, disinfection, and testing of the bypass waterlines and temporary service connections. The lump sum price shall include the cost for the CONTRACTOR to furnish and install all of the piping, gaskets, mechanical fittings, bends, tees, crosses, sleeves, reducers, transition couplings, caps, washout valve assemblies pipeline dewatering, concrete thrust blocks, thrust restraints, fittings and tubing for temporary service connections, excavation and removal of excess material, removal of all obstructions and appurtenances as specified, indicated, or implied on the plans, backfill as specified, and the flushing, disinfection, and testing of the waterline. Should the bypass waterline not meet the any of the District's requirements for flushing, disinfection, and/or testing the CONTRACTOR is responsible for correcting the deficiency. <p>Note: Payment also covers the complete removal and disposal of the bypass waterlines and temporary service connections following the commissioning of the permanent waterlines.</p>
3.	<p>Section 02565-2 BYPASS WATERLINES & TEMPORARY SERVICE CONNECTIONS</p>	<p>Delete Paragraph 201.01.C and replace with the following:</p> <p>Temporary bypass pipe shall be HPDE, PVC, or steel having a minimum working pressure rating of 200 psi with restrained couplings. The minimum size of bypass piping, fittings, and valves to be installed along Redmaple Road shall be of 6-inch diameter. The 6-inch diameter bypass piping is to be installed within a shallow trench, with minimum of 1-foot of cover or additional amount of cover as the Contractor deems necessary to adequately protect the bypass piping. The minimum size of bypass piping, fittings, and valves to be installed along 3680 South shall be of 2-inch diameter.</p>

4	PAGE D-1 Bid Bond	Delete second paragraph and replace with the following: WHEREAS, Principal has submitted a bid to Owner to perform all work required under the bidding Schedule of the Owner's Contract Documents entitled "2022 Distribution Pipeline Replacements Redmaple Area", (hereafter called the "Project Title"). The corrected Bid Bond form is attached.
---	--------------------------	--

This Addendum shall be incorporated into and made part of the Bidding Documents.

- END OF DOCUMENT -

BID BOND

KNOW ALL MEN BY THESE PRESENTS,

That _____
as Principal, and _____
as Surety, are held and firmly bound unto the Jordan Valley Water Conservancy District
(hereinafter called "Owner") in the sum of _____
dollars, (not less than five percent of the total amount of the bid) for the payment of which
sum, will and truly to be made, we bind ourselves, our heirs, executors, administrators,
successors, and assigns, jointly and severally, firmly by these presents.

WHEREAS, Principal has submitted a bid to Owner to perform all work required under
the bidding Schedule of the Owner's Contract Documents entitled "2022 Distribution
Pipeline Replacements Redmaple Area", (hereafter called the "Project Title").

NOW THEREFORE, if Principal is awarded Contract by Owner for the Construction of the
Project and, within the time and in the manner required under the heading "Instructions to
Bidders" enters into the written contract entitled "Agreement" bound with said Contract
Documents, furnishes the required certificates of insurance, and furnishes the required
Performance Bond and Payment Bond within 10 calendar days after receipt of such
contract from Owner, then this obligation shall be null and void, otherwise it shall remain in
full force and effect. In the event suit is brought upon this bond by Owner and judgment is
recovered, Surety shall pay all costs incurred by Owner in such suit, including a reasonable
attorney's fee to be fixed by the court.

SIGNED AND SEALED, this _____ day of _____, 20____.

By: _____ By: _____

Its: _____ Its: _____

(SEAL)

(SEAL)